

		二次診断 Is値	三次診断 Is値
X 方向	PH2 階	1.774	0.516
	PH1 階	0.848	0.612
	9 階	1.504	0.612
	8 階	1.529	0.612
	7 階	1.207	0.612
	6 階	0.977	0.612
	5 階	0.874	0.612
	4 階	0.715	0.597
	3 階	0.628	0.612
	2 階	0.718	0.575
	1 階	0.614	0.612
Y 方向	PH2	2.703	0.761
	PH1	0.993	0.756
	9 階	1.352	0.757
	8 階	1.384	0.726
	7 階	1.169	0.713
	6 階	0.867	0.67
	5 階	0.893	0.686
	4 階	0.746	0.675
	3 階	0.721	0.703
	2 階	0.838	0.731
	1 階	0.685	0.756